Quick Reference Guide

Adjusting the CG series burner




- 1. Must set per Spec Guide.
- 2. Must set air damper/air shutter.





3. Must set manifold gas pressure.






Note: V4944 gas valve is a regulating gas valve.

- 4. Must set breech draft to boiler manufacturer's recommendation.
- **5. Must** get combustion readings of 3 6% O_2 , 1-100 parts of CO.

Quick Reference Guide (continued)





R.W. Beckett Corporation • P.O. Box 1289 • Elyria, OH 44036 • PHONE 1-800-645-2876 • FAX 1-888-327-4811